



Institut pro testování a certifikaci, a.s.
Divize CSI - Centrum stavebního inženýrství

Fire Technical Laboratory

**AUTHORIZED
BODY**

**NOTIFIED
BODY**

CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH ČSN EN 13501-1:2019

Applicant: Highlite International BV
Vestastraat 2
NL – 6468 EX Kerkrade

Prepared by: Institut pro testování a certifikaci, a.s.
Divize CSI - Centrum stavebního
inženýrství
Pražská 16, 102 00 Praha 10
Czech Republic

Product name: *IFR Stretch 210 g/m²*

**Classification
report No.:** PK-24-137

Issue number: 1/2

Date of issue: 16th July 2024

This classification report consists of 4 pages and may only
be used or reproduced in its entirety.

Address:
PRAŽSKÁ 16, 102 00 PRAHA 10, Czech Republic, E mail: csias@csias.cz, <http://www.csias.cz>
Reg. No. 47910381, VAT No. CZ47910381.
Fire Technical Laboratory, E-mail: ptl@csias.cz
Phone: +420 281 017 111, Fax: +420 281 017 455

1. DETAILS OF CLASSIFIED PRODUCT

Nature and end use application:

The product, *IFR Stretch 210 g/m²*, is defined as a type of fabric without a closer end-use specification.

Description:

The product *IFR Stretch 210 g/m²* is fully described in the test reports in support of the classification listed in clause 2.

2. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

Test reports

Name of laboratory	Name of sponsor	Test report ref. no.	Test method
ITC, a.s., Divize CSI, AZL 1007.4	Highlite International BV	23/P701-1	ČSN EN ISO 11925-2
		23/P702-1	ČSN EN 13823

Measured values and test results:

Test method	Parameter	Number of test	Results	
			Continuous parameter mean (m)	Compliance parameters
ČSN EN ISO 11925-2 exposition = 30 s surface flame attack	$F_s \leq 150$ mm ignition of filter paper	18	yes	yes (B - D)
		18	no	yes (d2)
ČSN EN ISO 11925-2 exposition = 30 s edge flame attack	$F_s \leq 150$ mm ignition of filter paper	18	yes	yes (B - D)
		18	no	yes (d2)
ČSN EN 13823	$FIGRA_{0,2 MJ}$ (W/s)	3	2,5	≤ 120 (B)
	$LFS < \text{edge}$	3	yes	yes (B,C)
	$THR_{600 s}$ (MJ)	3	0,9	$\leq 7,5$ (B)
	$SMOGRA$ (m ² /s ²)	3	0	≤ 30 (s1)
	$TSP_{600 s}$ (m ²)	3	13,4	≤ 50 (s1)
	flaming droplets / particles	3	no	no (d0)

3. CLASSIFICATION AND DIRECT FIELD OF APPLICATION

Reference and direct field of application

This classification has been carried out in accordance with the clause 11.6, 11.9.2 and 11.10.1 of ČSN EN 13501-1:2019.

Classification

The product *IFR Stretch 210 g/m²*, in relation to its reaction to fire behaviour is classified:

B

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets/particles is:

d0

The format of the reaction to fire classification for *IFR Stretch 210 g/m²* is:

Fire behaviour		Smoke production			Flaming droplets	
B	-	s	1	,	d	0

Reaction to fire classification: B-s1, d0

Field of application:

This classification is also valid for the following product parameters:

- colour: without limitation

This classification is valid for the following end use conditions:

- without substrate

4. LIMITATIONS

Restrictions

This classification report is valid, provided that the technical specifications of the product will not be changed.

Warning

This document does not represent type approval or certification of the product.

Prepared:

.....
Jiří Socha



Reviewed:

.....
Vít Slaboch
head of laboratory